



Declaration of Performance

DoP number: SMOKEDUKE 2

1. The unique identifier of the product type: SMOKEDUKE™ –smoke extraction ducts
2. Intended use: Single compartment smoke extraction ducts, intended to use at either 600°C or in a fire situation.
3. Manufacturer: PK KANAVAT OY, Vanha Mikkeliintie 24 A, 76100 Pieksämäki, Finland, www.pkkanavat.fi
5. System of assessment and verification of constancy of performance: AVCP1
- 6 a. Harmonised standard: EN 12101-7:2011
- Notified body: PAVUS, a.s., No 1391
7. Declared Performance

Essential characteristics	Performance	Harmonised technical specification
Fire resistance	Single Compartment installations 1500 Pa – pressure level 3	12101-7
Integrity	E ₆₀₀ 120	
Installation director	h _o - v _e	
Insulation	-	
Smoke leakage	E ₆₀₀ 120 S	
Mechanical stability (under E)	Approved	
Maintenance of the cross section (under E)	Approved	

The performance of the product identified in point 1 is in conformity with the declared performance in point 7. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:



Pieksämäki 4th March 2025

Jorma Miettinen – Technical Director