



Declaration of Performance
DoP number: SMOKEDUKE 3

1. The unique identifier of the product type: SMOKEDUKE™ –smoke extraction duct
2. Intended use: Single compartment smoke extraction ducts, intended to use at either 600°C or in a fire situation.
3. Manufacturer: PK KANAVAT OY, Vanha Mikkeliintie 24 A, 76100 Pieksämäki, Finland, www.pkkanavat.fi
5. System of assessment and verification of constancy of performance: AVCP1
6 a. Harmonised standard: EN 12101-7:2011
Notified body: PAVUS, a.s., No 1391
7. Declared Performance

Essential characteristics	Performance	Harmonised technical specification
Fire resistance	Single Compartment installations 1500 Pa – pressure level 3	12101-7
Integrity	E ₆₀₀ 120	
Installation director	h _o -v _e	
Insulation	-	
Smoke leakage	E ₆₀₀ 120 S	
Mechanical stability (under E)	Approved	
Maintenance of the cross section (under E)	Approved	

The performance of the product identified in point 1 is in conformity with the declared performance in point 7. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:
Mikko Miettinen – CEO



Pieksämäki 17th April 2026

(place and date of issue)

(signature)